

Accident Sequence Precursor Analyses Of Taiwan Nuclear Power Plants

by
Yuan-Ching Chou and Ching-Hui Wu

2005 Asia-Pacific Conference on Risk Management and Safety

Outlines

- Introduction
- Data Source of Potential ASP
- Selection of Potential ASP
- Quantification of Potential ASP
- Results and Discussion
- Future Work

Introduction

- Probabilistic Risk Assessment
(PRA in nuclear industry, 1975~Today)
- Accident Sequence Precursor
(ASP of USNRC, 1979~Today)
- Major Purpose of ASP (SECY-04-0210):
“To identify, document and rank those nuclear power plant operating events that most likely to lead to inadequate core cooling and severe core damage, if additional failures had occurred”

Introduction (cont'd 1)

- **Major procedures of US ASP Analysis**
 1. A computerized search to identify LERs involving failures of core damage mitigation functions;
 2. An expert check to determine potential ASPs for detailed analysis;
 3. Quantification of potential ASPs by using Standardized Plant Analysis Risk (SPAR) models;
 4. Identification of ASPs; and
 5. Review and insight analysis of ASPs.

Introduction (cont'd 2)

- Quantified Criteria of ASP:
CCDP greater than 10^{-6} for precursors involving initiating event
 Δ CDP greater than 10^{-6} for precursors involving component failure
- Trend of US nuclear power plant core damage risk
(from FY1993 through FY 2002, SECY-04-0210)

CCDP $> 10^{-3}$

No trend

$10^{-3} > \text{CCDP} > 10^{-4}$

Decreasing trend – almost statistically significant

$10^{-4} > \text{CCDP} > 10^{-5}$

Decreasing trend – statistically significant

$10^{-5} > \text{CCDP} > 10^{-6}$

Increasing trend – statistically significant

Introduction (cont'd 3)

- **PRA development in Taiwan**

1. First PRA for the 2nd nuclear power plant (1982~1985, by AEC, TPC and INER)
2. PRA models for three nuclear power plants (1985~1991, by TPC and INER)
3. Living PRA for three nuclear power plants (1991~1996, by TPC and INER)
4. Risk informed applications of PRA (1996~today, AEC, TPC and INER)

Data Source of Potential ASP

- Atomic Energy Council annual reports
- Atomic Energy Council inspection reports
- Atomic Energy Council safety review reports
- Atomic Energy Council reportable event reports (RER)

Selection of Potential ASP

- 45 RERs for all three nuclear power plants from 2001 to 2005
- Criteria of exclusion from detailed analysis:
 1. Events occurred during reactor shutdown;
 2. Events involving containment system failure only;
 3. Events with no appreciable impact on safety system;
 4. Events involving shutdown by normal procedure.

Quantification of Potential ASP

- PRiSE (PRA Model Based Risk Significance Evaluation) model
 1. A fast running risk engine
 2. Plant specific risk models
 3. A tool for updating IE frequencies and failure prob.
 4. Calculation of risk indicators (CDP, CCDP, LERF)
 5. Calculation of risk importance (FV, RRW, RAW)
 6. Used by regulator, utility and research institute.

Front Line System

- RCIC
- HPCS
- ADS
- LPCS

RHR

- RHR System
- Train RHR-A RHR-B RHR-C

SBLC

- SBLC System
- Train SBLC-A SBLC-B

Support System

- COND
- CSTXR
- SGTS
- FIRE WATER

ECW

- ECW System
- Train ECW-A ECW-B

Power Supply

- 345KV D/G I
- 69KV D/G II
- D/G III
- BUS A5 D/G 5

A3

- Bus A3
- MCC C3A C3B

P&ID

Front Line System

- RCIC
- LPCS
- HPCS
- LPCI
- RHR S/D Cooling
- RHR S/P Cooling
- RHR CTMT Spray
- SBLC

Support System

- ECW
- EChW-A
- EChW-B
- Condensate
- CST Transfer
- SGTS
- FIRE WATER

Power Supply

- A3 Bus & D/G I
- A4 Bus & D/G II
- A5 Bus & D/G III
- D/G 5

系統失效狀態

A3 匯流排 (A3)

- A3 System Unavailable
- A3 Failure Rate Increase by

Status

System	Remark	Times of Increase

Clear All Change

元件失效率變更

Component :
 All Modified change to :

System :
 Times of Increase ? Times :

Component List

Description	Original	Modified	Times of Increase
▶ MOTOR-DRIVEN PUMP 1P-41A FAILS TO START	4.05E-03	1.00E-01	
PUMP(MOTOR DRIVEN) 1P-191A FAILS TO START	4.05E-03		
MOTOR-DRIVEN PUMP E12-1P-49A FAILS TO START	4.05E-03		
PUMP E21-1P83 FAILS TO START	4.05E-03		
MOTOR-DRIVEN PUMP 1P-4A (ECWS) FAILS TO START	4.05E-03	4.05E-01	100
PUMP 1VC-16A FAILS TO START (LOCAL FAULT)	4.05E-03		
MOTOR-DRIVEN PUMP 1P-41B FAILS TO START	4.05E-03		
PUMP(MOTOR DRIVEN) 1P-191B FAILS TO START	4.05E-03		
PUMP(MOTOR DRIVEN) E12-1P-49B FAILS TO START	4.05E-03		
MOTOR-DRIVEN PUMP E12-1P-49C FAILS TO START	4.05E-03		
MOTOR-DRIVEN PUMP 1P-4B FAILS TO START	4.05E-03		
MOTOR DRIVEN PUMP 1VC-16B (ECHW) FAILS TO START	4.05E-03		
PUMP(MOTOR DRIVEN) 1P-191C FAILS TO START	4.05E-03		
HPCS PUMP 1P-45 FAILS TO START	4.05E-03		
MOTOR-DRIVEN PUMP 1P116 FAILS TO START	4.05E-03		

Count : 2

Status

Description	Original	Modified	Times of Increase
▶ MOTOR-DRIVEN PUMP 1P-41A FAILS TO START	4.05E-03	1.00E-01	
MOTOR-DRIVEN PUMP 1P-4A (ECWS) FAILS TO START	4.05E-03	4.05E-01	100

Initiating Event

Description	Original	Modified	Times of Increase
IE : LARGE LOCA	3.00E-05		
IE : BYPASS LOCA	1.70E-07		
IE : RPV RUPTURE	2.70E-07		
IE : INTERMEDIATE LOCA	4.00E-05		
IE : SMALL LOCA	3.83E-03		
IE : MAIN CONDENSER ISOLATION TRANSIENT	2.15E-01		
IE : MSIVS CLOSED TRANSIENT	3.06E-02		
IE : MAIN STEAM NOT ISOLATION TRANSIENT	1.35E+00		
IE : LOSS OF OFFSITE POWER	3.15E-02	1.00E-01	
IE : INADVERTENT OPEN OF ONE S/RV (IORV)	4.68E-02		
IE : LOSS-OF-FEEDWATER	6.10E-02		
IE : LOSS OF 480V MCC 1C4C	2.01E-04	2.01E-02	100
IE : LOSS OF COMPRESSED AIR	2.20E-04		
IE : LOSS OF DC BUS 1RDC	6.70E-04		
IE : LOSS OF DC BUS 1GDD	6.70E-04		
IE : VLOCA AT LPCI INJECTION LINE A	4.28E-08		
IE : VLOCA AT LPCI INJECTION LINE B	4.28E-08		
IE : VLOCA AT LPCI INJECTION LINE C	3.29E-06		
IE : VLOCA AT RHR S/D COOLING SUCTION	1.52E-07		
IE : VLOCA AT RHR HEAD SPRAY INJECTION	3.29E-06		
IE : VLOCA AT RHR S/D COOLING INJECTION LINE A (FW A)	7.66E-06		
IE : VLOCA AT RHR S/D COOLING INJECTION LINE B (FW B)	7.66E-06		
IE : VLOCA AT LPCS INJECTION	3.29E-06		
IE : VLOCA INDUCED LARGE LOCA OUTSIDE CTMT	9.23E-09		
IE : VLOCA INDUCED LARGE LOCA INSIDE CTMT	9.44E-10		

Clear All Change

Refresh Frequencies

Save New Case

Previous Cases

Quote Cases Modified Cases Delete Cases

Quote Cases

Title :

Create Name : Administrator

Create Time : 2005/8/19 10:47:14 AM

Description :

Summary of Change

Operating Status Initiating Event Component Summary of Change Estimation Exit

System Operating Status

System	Remark	Times of Increase
▶ A3	A3 System Unavailable	

Initiating Event Frequencies

Description	Original	Modified	Times of Increase
▶ IE : LOSS OF OFFSITE POWER	3.149E-02	1.00E-01	
IE : LOSS OF 480V MCC 1C4C	2.010E-04	2.01E-02	100

Component

Description	Original	Modified	Times of Increase
▶ MOTOR-DRIVEN PUMP 1P-41A FAILS TO START	4.049E-03	1.00E-1	
MOTOR-DRIVEN PUMP 1P-4A (ECWS) FAILS TO START	4.049E-03	4.05E-01	100

Phase 2 Result



Results

CDF (Base Case) :

CDF (Modified) :

Difference :

Δ CDF

Exposure Time :

(Days)

Δ CDF :

Risk Information

Summary All Change

Minimum Cut Sets

Importance Analysis



System Operating Status

System	Remark	Times of Increase
▶ A3	A3 System Unavailable	

Initiating Event Frequencies

Description	Original	Modified	Times of Increase
▶ IE : LOSS OF OFFSITE POWER	3.149E-02	1.00E-01	
IE : LOSS OF 480V MCC 1C4	2.010E-04	2.01E-02	100

Component

Description	Original	Modified	Times of Increase
▶ MOTOR-DRIVEN PUMP 1P-44	4.049E-03	1.00E-1	
MOTOR-DRIVEN PUMP 1P-44	4.049E-03	4.05E-01	100

Results and Discussion

- Quantification results of potential ASP involving initiating events
- Quantification results of potential ASP involving component failures
- Insight of ASPs
- Discussion of all potential ASPs
- Discussion of a station blackout event

Table 1: Potential ASP Involving Initiating Event (2001 ~ 2005)

RER #	Plant (type)	Event Date	Description	CCDP
RER-94-31-001	3 rd (PWR)	3/25/05	Unit 1 general transient, main feedwater available, steam generator low-low level trip.	5.76E-7
RER-94-32-001	3 rd (PWR)	1/29/05	Unit 2 general transient, main feedwater available, reactor trip.	2.01E-7
RER-93-11-001	1 st (BWR)	1/24/04	Unit 1 general transient, main condenser not isolated.	1.93E-7
RER-92-32-07-0	3 rd (PWR)	12/9/03	Unit 2 general transient, main feedwater available, reactor trip.	2.01E-7
RER-92-31-003	3 rd (PWR)	9/1/03	Unit 1 general transient, main feedwater available, reactor trip.	2.01E-7
RER-92-31-004	3 rd (PWR)	9/4/03	Unit 1 loss of offsite power	6.01E-6
RER-92-32-003	3 rd (PWR)	9/1/03	Unit 2 general transient, main feedwater available, reactor trip.	2.01E-7
NA	1 st (BWR)	9/26/02	Unit 1 general transient, main condenser not isolated.	1.93E-7
NA	3 rd (PWR)	6/6/02	Unit 2 general transient, main feedwater available, reactor trip.	2.01E-7
NA	2 nd (BWR)	4/27/02	Unit 1 general transient, main condenser not isolated.	5.68E-7
NA	2 nd (BWR)	9/19/01	Unit 2 general transient, main condenser not isolated.	5.68E-7

Table 2: Potential ASP Involving Unavailability (2001 ~ 2005)

RER #	Plant (type)	Event Date	Description	Δ CDP
RER-94-12-002	1 st (BWR)	4/3/05	Unit 2 RCIC unavailable for 0.4 days	1.68E-8
RER-94-20-001	2 nd (BWR)	2/25/05	Unit 1 Loss of 69 kV power for 0.1 days Unit 1 Division III DG and HPCS unavailable for 0.76 days	1.45E-9 9.91E-8
RER-93-22-001	2 nd (BWR)	6/21/04	Unit 2 HPCS unavailable for 0.16 days	2.09E-8
RER-92-32-004	3 rd (PWR)	9/4/03	Unit 2 4.16kV Bus unavailable for 0.1 days	5.56E-7
RER-92-31-005	3 rd (PWR)	9/4/03	Unit 1 Feedwater isolation for 0.1 days	1.37E-10
RER-92-11-001	1 st (BWR)	1/21/03	Unit 1 HPCI unavailable for 16 days	1.09E-6
RER-92-11-002	1 st (BWR)	4/24/03	Unit 1 RCIC unavailable for 0.5 days	2.10E-8
RER-92-11-005	1 st (BWR)	7/24/03	Unit 1 HPCI unavailable for 1.0 days	6.82E-8
RER-92-11-006	1 st (BWR)	9/1/03	Unit 1 RCIC unavailable for 0.01days	4.19E-10
NA	2 nd (BWR)	9/5/01	Unit 1 Loss of 69kV power for 0.06 days	8.71E-10
NA	2 nd (BWR)	9/5/01	Unit 2 Loss of 69kV power for 0.06 days	8.71E-10

ASP Involving Initiating Event

- Date: September 4 of 2003
- Plant/Unit: The 3rd NPP/Unit 1
- Operating Condition: About to connect to the grid
- Initiating Event: A circuit breaker failure in switch yard causing a loss of offsite power (LOOP) event
- Dominant Sequence:
 1. RPS, RCS, TB driven AFW, ECCS and Depressurization system are successful
 2. Secondary heat removal system and bleed & feed function fail due to long term failure of emergency DGs

ASP Involving Unavailability

- Date: January 21 of 2003
- Plant/Unit: The 1st NPP/Unit 1
- Operating Condition: Full Power
- Unavailability: Fast-start test failure of HPCI system
(unavailable time is conservatively assumed as 16 days)
- Dominant Transient: Loss of feedwater event
- Root Cause: Vaporization of water in test line
- If the unavailable time is 1 day, then the Δ CDP becomes 16 times less.

Discussion of All Potential ASPs

- Potential ASP involving initiating event (Table 1)
 - 7 of 11 ASP candidates occurred in the 3rd NPP
 - 3 of these 7 events caused by failure of offsite power
 - 2 of these 7 events caused by failure of I&C cards
 - 2 of these 7 events caused by failure of FCV and TBCV
- Potential ASP involving component failure (Table 2)
 - 5 of 11 ASP candidates occurred in the 1st NPP
 - 3 of these 5 events caused by test failure of RCIC
 - 2 of these 5 events caused by test failure of HPCI
 - 3 out of 4 candidates from the 2nd NPP caused by failure of 69KV power supply

Discussion of A Station Blackout Event

- Date: March 18 of 2001
- Plant/Unit: The 3rd NPP/Unit 1
- Operating Condition: Shutdown
- Initiating Event: LOOP caused by a fire event at A-PB bus at unit 1
- Component Failure: 2 EDGs of unit 1 failed to supply power and caused a SBO event
- Termination: The 5th EDG lined up to the train-B switch of unit 1

Station Blackout Event (cont'd)

Table 3: Risk Analysis for 318 SBO Event (C.H. Wu et al.)

Analysis Stage	Operational Modes	Initiating Event	Time Duration	CCDP
1	Hot Standby	SBO	15 min.	3.1E-2
2	Hot Standby	SBO	1.75 hours	3.3E-3
3	Hot Standby	LOOP	4 hours	6.5E-4
4	Hot Shutdown	LOOP	11.5 hours	2.9E-4
5	Cold Shutdown	LOOP	52 hours	8.6E-5
6	Cold Shutdown	Partial LOOP	58 days	4.6E-8

Future Work

- To enlarge the scope of data source;
- To establish formal review processes of selection of potential ASPs;
- To include shutdown condition into the scope of analysis; and
- To set up a peer review procedure for the whole analysis.