

Level 1 PSA External Events Accident Sequence Quantification for Point Lepreau Refurbishment

*M. Wei, S. Sawh, A. Nainer, L. Comanescu, B. S. Lee,
E. Elewini, I. Vencel, G. Banaseanu, J. Ha, R. K. Jaitly
AECL*

*A. Jean, D. Basque, D. Mullin
NB Power*

May 19, 2008



UNRESTRICTED



AECL EACL



Agenda

- **Introduction to PLR PSA**
- **Level 1 External Events**
 - **Internal Fire Events**
 - **Fire-induced SCDF**
 - **Internal Flood Events**
 - **Flood-induced SCDF**
 - **Seismic Events**
 - **Seismic capacity of the plant expressed as HCLPF**



Point Lepreau Generating Station

- **NB Power is the utility**
- **Commercial operation 1983**
- **Provides 1/3rd of power consumed in province of New Brunswick**
- **Refurbishment plan: 18 month outage that started March 28 2008**





Introduction to PLR PSA

- **As part of the Refurbishment Project, a Level 2 PSA has been performed**
- **Scope includes:**
 - **internal events for full power and shutdown**
 - **internal fire and flood for full power only**
 - **PSA based Seismic Margin Assessment**
- **Note external fires and floods are included in another analysis for common mode failures**



Team Effort

- **Both AECL & NB Power's PSA analysts are participating in the PSA**
 - NB Power reviews all methodologies and analysis reports
 - Data for the models provided by NB Power
 - Accident Sequence Quantification: joint exercise
 - Both teams attend meetings with regulator as needed





Level 1 and 2 PSA Goals and Limits

- **Severe Core Damage Frequency (SCDF) from Internal and External Events:**
 - Limit: 1E-04 events/year
 - Goal: 1E-05 events/year
- **Large Release Frequency (LRF) from Internal and External Events:**
 - Limit: 1E-05 events/year
 - Goal: 1E-06 events/year
- **Seismic Margin corresponding to a High Confidence Low Probability of Failure (HCLPF)**
 - 0.3g for Severe Core Damage
 - 0.4g for Large Releases



Level 1 – Internal Fire Events

- **91 fire compartments considered**
- **9 fire compartments screened out from qualitative screening analysis**
- **64 fire compartments screened out from quantitative screening analysis**
- **From 18 remaining fire compartments, 916 initiating events screened out, 314 screened in**
- **314 fire initiating events correspond to 95 fire scenarios**
- **95 fire scenarios retained for detailed analysis**
 - 12 in Reactor Building
 - 42 in Turbine Building
 - 41 in Service Building



Fire Detailed Analysis

- **Develop event trees**
 - Identify mitigating systems unavailable due to fire
- **Create fault trees specific to the fire scenario to reflect partial systems failures**
- **Accident sequence quantification to estimate fire-induced SCDF**




Fire Event Tree Models

- **Termination of Level 1 accident sequences are classified as plant damage states (PDS)**
- **Originally, 11 different PDS were defined for internal events analysis**
 - **No fuel damage but economic consequences**
 - **Limited fuel damage with economic consequences**
 - **Widespread fuel damage**
 - **Severe core damage**
 - **Failure to shutdown**
 - **Loss of heat sinks**



Fire Fault Tree Models

- Master fault tree for internal events contains all mitigating and support system fault tree models
- Modify existing internal events master fault tree to cater to the fire scenario
- Removing branches in the model to reflect failed devices and components





Accident Sequence Quantification

- **Quantify severe core damage sequences**
- **Remove mutually exclusive events from cutsets**
- **Adjust human error probabilities (HEPs) for operator actions located in the fire vicinity**
- **Adjust HEPs for dependency using SPAR-H**
- **For recalculate dominant contributors using less conservative methodologies**
 - Alpha method for common cause failures
 - THERP for HEPs
- **Credit recovery factors**




Level 1 – Internal Fire Results

Location	Fire-induced Severe Core Damage Frequency (events/year)
Reactor Building <small>*with proposed design change</small>	4.13E-06
Turbine Building	1.50E-05
Service Building	1.24E-05
Total	3.15E-05



Fire Contributors to SCDF





Level 1 – Internal Flood Events

- **All possible sources of water were systematically reviewed including large tanks**
- **Qualitative screening**
- **Quantitative screening**
- **21 flood scenarios retained for detailed analysis**
 - **Condenser Cooling Water**
 - **Raw Service Water**
 - **Only 2 open circuits in CANDU plants both of which are in Turbine Building**



Flood Detailed Analysis

- **Develop event trees**
 - Operator actions and mitigating systems to stop the flooding
 - Identify mitigating systems unavailable due to flood
- **Use existing ASQ master fault tree for internal events**
- **Accident sequence quantification to estimate flood-induced SCDF**



Level 1 – Internal Flood Results

Type of Flood	Flood Induced SCDF (events/year)	Contribution to SCDF
RSW 12" Isolable Break	9.48E-07	79.9%
RSW 24" Isolable Break	1.60E-07	13.5%
RSW 24" Non-Isolable Break	2.56E-08	2.2%
CCW 60" Outlet Break	2.22E-08	1.9%
CCW 60" Inlet Break	1.87E-08	1.6%
RSW 12" Non-Isolable Break	9.20E-09	0.8%
CCW 60" Non-Isolable Break	3.18E-09	0.3%
Total (events/year)	1.18E-06	




PSA-Based Seismic Margin Assessment

- **Measures the robustness of PLGS to withstand earthquakes of a given g-level**
- **Establish the Safe Shutdown Equipment List (1400 items)**
- **Seismic Walkdown**
 - **Screen out 1000 items from Safe Shutdown Equipment List (SSEL) using EPRI NP-6041-SL**
 - **Equipment and structures whose structural failure may impact nearby items that are on SSEL**
- **Fragility Analyses to determine seismic capacity of structures and components not screened out (400 items)**



Seismic Fault Tree Models

- ASQ Master fault tree for internal events contains all mitigating and support system fault tree models
- Modify existing ASQ Master fault tree by adding seismic failures (functional and structural failures)
- Modify the HRA values





Seismic Margin Results

- **Quantify using the min-max method**
- **PLGS HCLPF is 0.34g**
- **Limited by seismic capacity of dousing tank**
 - **Crack in the dousing dome leads to leaks of dousing inventory, which is necessary for the boiler makeup water system**
 - **Seismic capacity of backup heat sink is 0.31g**
 - **Loss of heat sinks lead in severe core damage**



- **Results of Level 1 internal fire and flood events summed with Level 1 internal events at full power**

	Severe Core Damage Frequency (events/year)
Internal Events	1.66E-05
Internal Fire Events	3.15E-05
Internal Flood Events	1.18E-06
Total	4.93E-05

- **Results of Level 1 are the input to Level 2**



- **Thank you for your attention**
- **Questions?**